FLOOR WALL INTERSECTION FLAT FLOOR FREEZER SIDE VIEW SILICONE OR URETHANE SEALANT **WARM SIDE CURB 6 MIL POLYETHELENE** SLIP SHEET FINISHED FLOOR **URETHANE SEALANT** (BY OTHER) COLD SIDE 1/4" FIELD CUT -THERMAL BREAK URETHANE SKINNING α CAULK 쩹 1/4-14 x 7/8" **TEK SCREW NON SKINNING BUTYL CAULK** 0025 - 26 GAUGE-**EXTERIOR PERIMETER** BASE CHANNEL DRIP **EDGE FLASHING** PERMATHERM VAPOR **BARRIER TAPE** CONCRETE ANCHOR BOLT **GRADE** 12" ON CENTER 10 MIL POLY VAPOR BARRIER 2" *NOT BY PERMATHERM STAGGER JOINT, WITH NON SKINNING, CAULK IN STAGGER. MUD SLAB DOUBLE LAYER OF PERMATHERM 2 LB. FLOOR INSULATION. LAYERS ARE STAGGERED 269 Industrial Park Road ANDTAPED WITH VAPOR BARRIER TAPE. Monticello, GA 31064 DETAIL: No. 2860 This detail is commonly used for this application; however, every building

project is different. You should consult your building engineer to make sure this detail will work for your particular application.

FLOOR WALL INTERSECTION FLAT FLOOR FREEZER

Contents and logo are property of PermaTherm, Inc. All rights reserved. Copyright 2025 ©